

The Head  
Department of Microbiology  
PAU, Ludhiana.

The Principal  
Sri Guru Harkrishan Public School  
Model Town Extension-D, Dugri Road  
Ludhiana

Memo. No. 33/3  
Dated: 17/07/23

Subject: Bacteriological quality of drinking water (IS-10500:1991, BIS New Delhi).

Reference is made to your letter No. sgfps/23/1308 dated 12.07.2023 regarding sample of water for bacteriological analysis.


REPORT

Sl. No.	Source	Coliform organisms		Faecal Coliform / E. coli Detected / Not detected
		Present/ Absent	Most Probable Number index ( $<10/100\text{ml}$ )	
01	Water sample	Absent	--	Not Detected

REFERENCE

Bacteriologically safe :- 01  
Bacteriologically not safe :- nil

Amrinder Singh  
Technician  
Water Testing Lab  
Department of Microbiology  
PAU, Ludhiana

  
Incharge  
Water Testing Lab  
Department of Microbiology  
PAU, Ludhiana

NOTE: This result relates to the sample provided to us and laboratory is not responsible for wrong collecting of samples. The contents of this report are meant for your guidance and should not be used for Advertisement, Evidence and Litigation. This test document shall not be reproduced without the permission of the University.



Head  
Department of Microbiology

Treatment for non-potable water as per WHO recommendations: Treat 20L of water with 1mL dose of 10% Sodium hypochlorite or 1.8mL dose of 5% Sodium hypochlorite solutions with retention time of 30 Mins. The water must be used within 24 hours of treatment. The solution is available with all the chemical stores